

ANALYTICAL LABORATORY



NABL Accredited Laboratory Testing of Food, Water, Natural products & Shelf life study ISO 9001:2015 & ISO 14001:2015.

TEST REPORT

Lab Id No.: VAL/2112/0531

Name & Address

	Report Date: 18/12/2021			
Receipt Date	Analysis Start Date	Analysis End Date		
17/12/2021	17/12/2021	18/12/2021		

Particulars of Sample Submitted

C P Goenka International School. IC Colony, Off Link Road,

- 1) Sample Name: Water (BMC)
- 2) Batch No/Lot No:- Not specified
- 3) Other Information:- NA

Borivali (W) - 400103.

4) Sample Quantity:- Approx 1 Litre

- 5) Description:- Sample packed in plastic bottle.
- 6) Sample submitted by:- Sample collected by lab personnel Sunil.7) Date of collection:- 17/12/2021

Analysis Results

Sr. No.	Tests	Results	Specification as per IS 10500:2012	Unit	Method Reference
	cipline - Chemical Testing Group - Water	2 2			
	2 To x		Physical		
1	Colour	ND<1.0	Max - 5	Hazen	IS 3025 (part 4) 1983
2	Taste	Agreeable	Agreeable		IS 3025 (part 8) 1984
3	Odour	Agreeable	Agreeable		IS 3025 (part 5) 1983
			Chemical		4 /
4.	pН	8.02	6.5 - 8.5		IS 3025 (part 11) 1983
5	TDS	61.0	Max - 500	mg/l	IS 3025 (part 16) 1984
6	Turbidity	ND<0.5	Max -1	NTU	IS 3025 (part 10) 1984
7.	Total Hardness	47.0	Max - 200	mg/l	IS 3025 (part 21) 2009
8	Chlorides	12.83	Max - 250	mg/l	IS 3025 (part 32) 1988
9	Total Alkalinity as CaCO ₃	44.0	Max - 200	mg/l	IS 3025 (part 23) 1986
10	Calcium	10.42	Max - 75	mg/l	IS 3025 (part 40) 1991
11	Fluoride	ND<0.1	Max-1.0	mg/l	IS 3025 (Part 60) 2008
12	Sulphate	ND<2.0	Max - 200	mg/l	IS 3025 (Part 24) 1986
13	Silica	ND<0.01	Not Specified	mg/l	IS 3025 (part 35) 1988
14	Magnesium	5.10	Max - 30	mg/l	IS 3025 (part 46) 1994
15	Conductivity	125.8	Not Specified	μs/cm	IS 3025 (part 14) 1984

Reference No.: VAL/TC/21120531-1, ULR - TC542621000008351F

.....Cont.....

Page 1 of 2



VARNI

ANALYTICAL LABORATORY



NABL Accredited Laboratory
Testing of Food, Water, Natural products & Shelf life study
ISO 9001:2015 & ISO 14001:2015.

	ipline - Biological Testing Froup - Water	g	2.3		
. 9	(1)	N	Iicrobiological		
16	E. Coli	Absent <1	Absent	Cfu/100m1	IS - 15185 : 2016
17	Total Coliform	Absent <1	Absent	Cfu/100ml	IS - 15185 : 2016

Remarks: - From the above values we confirm that the water passes in parameters to IS 10500:2012. Hence sample is fit for human consumption in above respective parameters only.

Note:

1. Results pertain only to the sample tested. Test report shall not be reproduced except in full, without written approval of the Technical Manager. 2. Sample not drawn by VAL representative. 3. Sample(s) will be retained by us for a period of 15 days for non-perishable items only. Perishable items will be destroyed after completion of test. 4. Subject to Thane Jurisdiction. 5. ND – Not detected, BLQ - Below limit of quantification, NMT – Not more than, NLT – Not less than.

Approved by Sheetal Panhalkar (Micro, Authorised signatory) MIRA ROAD

Approved By Virendra Vora (QM, Authorized signatory)

Reference No.: VAL/TC/21120531-2, ULR - TC542621000008351F

....End of Report.....

Page 2 of 2